



**NOTES**

1. CLASS II A.B. OR 1½" DRAIN ROCK TO BE PLACED UNDER CHRISTY BOX HAVING A 4" MIN. THICKNESS
2. METER BYPASS SHALL BE REQUIRED FOR DOMESTIC SERVICES THAT ARE 3-INCHES OR GREATER.
3. METER BYPASS IS NOT REQUIRED FOR IRRIGATION SERVICES.
4. METER BYPASS SHALL BE REQUIRED FOR FIRE SERVICES THAT ARE 3-INCHES OR GREATER, UNLESS OTHERWISE APPROVED BY THE FIRE MARSHALL. METER BYPASS SHALL BE REQUIRED FOR FOR FIRE SERVICES ON PROJECTS WITH AN ONSITE FIRE SYSTEM AND PRIVATE HYDRANT(S).



*City of San Bruno*  
Standard Detail

**METER BYPASS FOR  
3" SERVICE OR GREATER**

CITY ENGINEER:

*Hae Won Ritchie*  
APPROVED BY: HAE WON RITCHIE R.C.E. C69532

DATE: FEB 2021

DRAWN BY: JMH

**W-09**

DETAIL NO: